



**TECHNICAL DATA**

<b>According Standard</b>	<b>EN-61.558-2-15</b>
<b>Rated Power</b>	<b>5000 VA</b>
<b>Primary Voltage</b>	<b>230V</b>
<b>Secondary Voltage</b>	<b>230V</b>
<b>Frequency</b>	<b>50/60 Hz</b>
<b>Protection Grade</b>	<b>IP-00</b>
<b>Isolement Level</b>	<b>F</b>
<b>ED:</b>	<b>100%</b>
<b>ta</b>	<b>40°C</b>
<b>Ucc</b>	<b>8%</b>
<b>Protection temperature</b>	<b>NC 130°C</b>
<b>Strength Dielectric test between live parts</b>	<b>4.500V</b>
<b>Strength Dielectric test between live parts and mass</b>	<b>4.500V</b>
<b>Data Plate</b>	<b>Yes</b>
<b>Electrostatic screen</b>	<b>Yes</b>
<b>Wound wires</b>	<b>Cooper wire G-2 class H</b>
<b>Magnetic Core</b>	<b>Non oriented grain, cold lamination. M 330-50A EN10106</b>
<b>Bobbin</b>	<b>PA6 + Glass Fiber (30%)</b>
<b>Type Refrigeration</b>	<b>Dry</b>
<b>Connection</b>	<b>-</b>
<b>Terminal block</b>	<b>CONTA CLIP 6mm (PRI) CONTA CLIP 6mm (SEC)</b>
<b>Weight</b>	<b>40 Kg.</b>

<b>Drew by:</b> Miguel A. Hdez. - 31/01/2024	<b>Approved by:</b> Victor Gallego - 31/01/2024	
<b>I-PHASE TRANSFORMER FOR MEDICAL LOCATIONS</b>		
<b>Units:</b> mm.	<b>TD802503200</b>	
Page 1 de 1 Rev: 01 Rev date.: 31/01/2024	MANUMAG SL - C/Antonio Barriendos s/n, Pol. Ind. Las Norias 50450-MUEL, SPAIN - VAT ESB50040146 Tel +34 976 140606 - Fax +34 976 140 607 comercial@manumag.com, export@manumag.com	